LABOR RELATIONS DIVISION **WWW.DWS.STATE.NM.US**

401 Broadway NE
Albuquerque, NM 87102
Phone: 505-841-4400
Fax: 505-841-4424

226 South Alameda Blvd
Las Cruces, NM 88005
Phone: 575-524-6195
Fax: 575-524-6194

1596 Pacheco St, Suite 103
Santa Fe, NM 87505
Phone: 505-827-6817
Fax: 505-827-9676

Wage Decision Approval Summary

1) Project Title: Loving MS Honeywell HVAC Upgrades
Requested Date: 10/04/2021
Approved Date: 10/05/2021
Approved Wage Decision Number: ED-21-1998-B

Wage Decision Expiration Date for Bids: 02/02/2022

2) Physical Location of Jobsite for Project:
Job Site Address: 602 S 6th ST
Job Site City: Loving
Job Site County: Eddy

3) Contracting Agency Name (Department or Bureau): Loving Municipal Schools
Contracting Agency Contact's Name: Veronica Carrasco
Contracting Agency Contact's Phone: (575) 745-2008 Ext.

4) Estimated Contract Award Date: 06/28/2021

5) Estimated total project cost: $541,359.37
a. Are any federal funds involved?: No
b. Does this project involve a building?: Yes - Installation of 30 new rooftop ventilation/air-conditioning/ Warm-up systems with full economizers and hail guards.
c. Is this part of a larger plan for construction on or appurtenant to the property that is subject to this project?: No
d. Are there any other Public Works Wage Decisions related to this project?: No
e. What is the ultimate purpose or functional use of the construction once it is completed?: HVAC upgrades to help school ventilation.

6) Classifications of Construction:

Classification Type and Cost Total	Description
General Building (B) **Cost:** $541,359.37	Provide and replace 19 existing 3-ton rooftop package units, 3 existing 4-ton rooftop package units, 4 existing 5-ton rooftop package units, and existing 2 6 -ton rooftop package units with 14 SEER Daikin units with full economizers and hail guards. Provide and replace 2 12.5 ton rooftop pack units with 11.3 EER Daikin units with full economizers, hail guards and Merv13 filters. Removal and disposal of the existing RTU's. Verify existing electrical and gas connections to the existing RTU's.